



HOW TO AVOID RELAY MISOPERATIONS DUE TO WRONG SETTINGS OR FIRMWARE BUGS

J. Holbach May 2019
RTDS User Group Meeting in Denver



Smart Solutions, Practical Results

Overview

- Introduction
- Test Application
- Results
- Test Automation Process
- Conclusion

Smart Solutions, Real Results


- Premium technical & business consulting
- Independent arm of Quanta Services
- Industry thought leaders: practical experts
- Headquarters in Raleigh, NC
- U.S. and international regional offices
- Extensive T&D Experience

We are . . .

- Seasoned staff including former utility executives and engineers with 25+ years of practical experience serving utility industry
- Talented mid-level and junior staff poised to become industry leaders
- Many patents, books and published articles
- Thought leaders, actively involved in development of industry standards and evolving planning and operation practices
- Advanced Degrees, Professional Licenses & Certifications (PhD, PE, MBA, PMP), IEEE Fellows

Quanta Technology Locations


Strategically located operations serve the North American utility base



RTDS Testing – Latest Project

Alberta PowerLine


Fort McMurray West 500 kV Transmission Project



Test Application

- Test included test of protection and control devices for two 500kV transmission lines
 - 12L41 is a ~415km shunt compensated transmission line connecting Livock substation to Sunnybrook substation (an AltaLink owned/operated substation)
 - 12L44 is a ~100km shunt compensated transmission line connecting Livock substation to Thickwood Hills substation
 - Shunt reactors are installed at each line terminal
 - 500kV line protection is provided by two primary distance protection systems using Siemens 7SA522 devices for system 'A' and SEL-421-5 devices for system 'B'.
 - The systems utilize high-speed communications assisted permissive over-reaching transfer trip (POTT), direct under-reaching transfer trip (DUTT) and direct transfer trip (DTT) schemes with time graded stepped distance elements for communications independent backup protection
 - Shunt Reactor Protection include the REC670 and SEL-487E devices

RTDS HMI




Alberta PowerLine : HIL Test Set-Up



New RTDS Shunt Reactor Model

Non-Linear model of Shunt Reactor




Name	Description	Value	Unit
Name	Component Name	SR1A	
TName	Terminal Label	A	
cnfg	Format of Reactor Electrical Data Input:	MVAR	
VbsIn	Rated RMS Line-to-Neutral Voltage:	303.11	kV
HTZ	Base Frequency:	60.0	Hertz
Rmvar	Rated MVAR of the Reactor:	16.7	MVAR
XSR	Reactor Total Reactance	387.2	Ohm
CuL	Copper Losses:	2e-3	p.u.
Coretyp	Type of the Reactor Magnetic Core	Iron Core	
satur	Specification of Reactor Saturation Curve	Points	
XI	Reactor Leakage Reactance	0.3	p.u.
MfacAir	Mutual Coupling Coefficient of Sub-Windings (<1.0) for Air-Path Flux	0.0	
FLTprc1	Percentage of the 1st Point of Fault from the Neutral	50	%
FLTprc2	Percentage of the 2nd Point of Fault from the Neutral	30	%
Icon	Show component icons as	Small	


- It contains three sub-windings and two junction nodes in addition to the terminal nodes.
- The model allows users to apply **turn-to-turn** and turn-to-ground faults for a single-phase shunt reactor.
- The user has the option of specifying reactor core type: air-core or iron-core.

Communication Delay Simulation

- A communication latency of 16 ms had to be simulated
- Logic of relay cannot be changed for test!



- No commercial solution was available-> Quanta Technology developed customized solution for this test



Test Plan-Functional Tests

- 7.1 12L41 Line Protection Functional Tests..... 19
 - 7.1.1 Basic Internal Faults 20
 - 7.1.2 Basic Internal Resistive Faults 22
 - 7.1.3 Permanent Internal Resistive Faults 25
 - 7.1.4 External Faults 26
 - 7.1.5 Evolving Faults 28
 - 7.1.6 Breaker Failure – Fails to open..... 30
 - 7.1.7 Breaker Failure – Fails to close 31
 - 7.1.8 Switch-Onto-Fault 32
 - 7.1.9 Power Swing Blocking Test 33
 - 7.1.10 Communication Failure 34
 - 7.1.11 Energization from Thickwood Hills 36
- 7.2 12L41 Shunt Reactor Protection Functional Tests 37
 - 7.2.1 APL Livock 12L41 Terminal Shunt Reactor: Internal Faults 37
 - 7.2.2 APL Livock 12L41 Terminal Shunt Reactor: Line Switching 39
 - 7.2.3 AML Sunnybrook 12L41 Terminal Shunt Reactor: Internal Faults 40
 - 7.2.4 AML Sunnybrook 12L41 Terminal Shunt Reactor: Switching Onto Internal Faults 42
- 7.3 12L41 Protection Operating Time Batch Tests 43

7.1.1 Basic Internal Faults

- Temporary metallic internal faults
- Fault duration = 200 ms (12 cycles)
- Only fast communication channel is active in Siemens and SEL protection
- Cases #1a, #1b: Heavy load with system normal is simulated
- Faults locations H (note: locations I and K are considered in reactor functional tests).

Table 7-1-1: Internal Faults

Test Case #	Fault Location	Percent	Fault Type	Fault Duration [cycle]	Fault Angle	Fault Resistor	Load
L41_1101	H	0.00	BG	12	0	0.01	Case#1a
L41_1102	H	0.00	AG	12	0	0.01	Case#1b
L41_1103	H	0.00	ABG	12	30	0.01	Case#1b
L41_1104	H	0.00	BC	12	60	0.01	Case#1a
L41_1105	H	0.00	ABC	12	90	0.01	Case#1b
L41_1106	H	10.00	BG	12	0	0.01	Case#1a
L41_1107	H	10.00	CG	12	0	0.01	Case#1b
L41_1108	H	10.00	BCG	12	30	0.01	Case#1b
L41_1109	H	10.00	CA	12	60	0.01	Case#1a
L41_1110	H	10.00	ABC	12	90	0.01	Case#1b
L41_1111	H	30.00	CG	12	0	0.01	Case#1a
L41_1112	H	30.00	AG	12	0	0.01	Case#1b
L41_1113	H	30.00	CAG	12	30	0.01	Case#1b
L41_1114	H	30.00	AB	12	60	0.01	Case#1a
L41_1115	H	30.00	ABC	12	90	0.01	Case#1b
L41_1116	H	50.00	AG	12	0	0.01	Case#1a
L41_1117	H	50.00	CG	12	0	0.01	Case#1b
L41_1118	H	50.00	ABG	12	30	0.01	Case#1b
L41_1119	H	50.00	BC	12	60	0.01	Case#1a
L41_1120	H	50.00	ABG	12	90	0.01	Case#1b
L41_1121	H	70.00	AG	12	0	0.01	Case#1a
L41_1122	H	70.00	BG	12	0	0.01	Case#1b
L41_1123	H	70.00	ABG	12	30	0.01	Case#1b
L41_1124	H	70.00	BC	12	60	0.01	Case#1a
L41_1125	H	70.00	ABC	12	90	0.01	Case#1b
L41_1126	H	90.00	AG	12	0	0.01	Case#1a
L41_1127	H	90.00	BG	12	0	0.01	Case#1b
L41_1128	H	90.00	ABG	12	30	0.01	Case#1b
L41_1129	H	90.00	BC	12	60	0.01	Case#1a
L41_1130	H	90.00	ABC	12	90	0.01	Case#1b
L41_1131	H	100.00	BCG	12	0	0.01	Case#1a
L41_1132	H	100.00	CA	12	30	0.01	Case#1b
L41_1133	H	100.00	ABC	12	60	0.01	Case#1a
L41_1134	H	100.00	CG	12	90	0.01	Case#1b
L41_1135	H	100.00	BG	12	90	0.01	Case#1a

Test Plan-Batch Tests

7.1	12L41 Line Protection Functional Tests.....	19
7.1.1	Basic Internal Faults	20
7.1.2	Basic Internal Resistive Faults	22
7.1.3	Permanent Internal Resistive Faults	25
7.1.4	External Faults	26
7.1.5	Evolving Faults.....	28
7.1.6	Breaker Failure – Fails to open.....	30
7.1.7	Breaker Failure – Fails to close.....	31
7.1.8	Switch-Onto-Fault	31
7.1.9	Power Swing Blocking Test	31
7.1.10	Communication Failure	31
7.1.11	Energization from Thickwood Hills	31
7.2	12L41 Shunt Reactor Protection Functional Tests	31
7.2.1	APL Livock 12L41 Terminal Shunt Reactor: Internal Faults	31
7.2.2	APL Livock 12L41 Terminal Shunt Reactor: Line Switching	31
7.2.3	AML Sunnybrook 12L41 Terminal Shunt Reactor: Internal Faults.....	31
7.2.4	AML Sunnybrook 12L41 Terminal Shunt Reactor: Switching Onto Internal Fau.....	31
7.3	12L41 Protection Operating Time Batch Tests.....	31

7.3 12L41 Protection Operating Time Batch Tests

After the functional testing, the final settings will be tested with extensive operating time batch tests simulating internal line faults and external system faults. The batch tests shall be configured to simulate the conditions listed below.

Internal Batch Tests (Per Appendix D of the AESO Functional Specification)

- Three fault locations will be tested: H(0%), H(50%) and H(100%)
- At each fault location all ten fault types are to be applied: AG, BG, CG, AB, BC, CA, ABG, BCG, CAG and ABC
- Ground faults will consider 0Ω fault resistance (per AESO documentation, defined clearing times for ground faults are for solid ground faults)
- For each fault type the following fault inception angles are to be applied: 0, 10, 20, 30, 40, 50, 60, 70, 80, 90, 100, 110 and 120 deg. of phase A
- The above tests will be carried out considering the following load flow/system contingency cases: #1a, #1b, #3, #4 and #5
- Each test will include line energization with a stabilization period (>4s) followed by the fault event. Energization from both terminals is possible, thus, tests will be configured in a way that energization will be simulated from alternating terminals.

External Batch Tests

- Six fault locations will be tested: C(0%), A(50%), A(100%), L(0%), L (100%), M(100%)
- At each fault location all ten fault types are to be applied: AG, BG, CG, AB, BC, CA, ABG, BCG, CAG and ABC
- Ground faults will consider 0Ω fault resistance
- For each fault type the following fault inception angles are to be applied: 0, 30, 60, 90 deg. of phase A
- The above tests will be carried out considering the following load flow/system contingency cases: #1a, #1b, #3, #4 and #5
- Simulated adjacent clearing times to include: high speed clearing (i.e. communications assisted) and delayed clearing (i.e. communications failure or breaker failure).

AESO Timing Requirements

Location	Multi-phase Faults	Single Line To Ground Faults
Line Near-end Clearing Time	3.5 cycles	4.5 cycles
Line Far-end Clearing Time	4.5 cycles	5.5 cycles
Substation Fault Clearing Time	3.5 cycles	4.5 cycles
Breaker Failure Near-end Clearing Time	9.0 cycles	10.0 cycles
Breaker Failure Far-end Clearing Time	10.0 cycles	11.0 cycles




Test Results

- Approx. 3500 cases were tested in 3 weeks
- During functional Test (ca. 200 tests)
 - 2 critical setting problems where found
 - Switch onto fault pick-up level was to sensitive
 - Overreach of zone 1
 - 5 setting improvements where detected and implemented
 - Incorrect logic
 - Timer adjustments
- **One critical firmware issue was found during sophisticated batch test of 3500 test (requirement of AESO)**
 - Firmware bug caused wrong direction determination for external fault
 - Quanta Technology supported customer and manufacturer during the revision of the firmware
- Communication delay simulation devices was developed particular for this test

Result Table for 1200 External Faults


	Case	Line	Location	Type	Resistor	Angle	Load					REC670 Close	REC670 Trip Reactor	1206 52A A (RTDS)	1206 52A B (RTDS)	1206 52A C (RTDS)	1207 52A A (RTDS)	1207 52A B (RTDS)	1207 52A C (RTDS)	
BatchEx	245	C	0	2	0.001	0	1b 1 0	1	LivockLine1	245	1044.48	Low	High	43.52	High	High	43.52	High	High	
BatchEx	323	A	100	1	0.001	60	1b 1 0	1	LivockLine1	323	1036.16	Low	High	43.52	High	High	43.52	High	High	
BatchEx	324	A	100	1	0.001	90	1b 1 0	1	LivockLine1	324	1035.52	Low	High	42.88	High	High	42.88	High	High	
BatchEx	325	A	100	2	0.001	0	1b 1 0	1	LivockLine1	325	1040	Low	High	42.88	High	High	42.88	High	High	
BatchEx	346	A	100	7	0.001	30	1b 1 0	1	LivockLine1	346	Low	Low	42.88	42.88	42.88	42.88	42.88	42.88	42.88	
BatchEx	350	A	100	8	0.001	30	1b 1 0	1	LivockLine1	350	Low	Low	42.88	43.52	43.52	42.88	43.52	43.52	43.52	
BatchEx	1	C	0	1	0.001	0	1a 1 0	0	LivockLine1	1	Low	Low	High	High	High	High	High	High	High	
BatchEx	2	C	0	1	0.001	30	1a 1 0	0	LivockLine1	2	Low	Low	High	High	High	High	High	High	High	
BatchEx	3	C	0	1	0.001	60	1a 1 0	0	LivockLine1	3	Low	Low	High	High	High	High	High	High	High	
BatchEx	4	C	0	1	0.001	90	1a 1 0	0	LivockLine1	4	Low	Low	High	High	High	High	High	High	High	
BatchEx	5	C	0	2	0.001	0	1a 1 0	0	LivockLine1	5	Low	Low	High	High	High	High	High	High	High	
BatchEx	6	C	0	2	0.001	30	1a 1 0	0	LivockLine1	6	Low	Low	High	High	High	High	High	High	High	
BatchEx	7	C	0	2	0.001	60	1a 1 0	0	LivockLine1	7	Low	Low	High	High	High	High	High	High	High	
BatchEx	8	C	0	2	0.001	90	1a 1 0	0	LivockLine1	8	Low	Low	High	High	High	High	High	High	High	
BatchEx	9	C	0	3	0.001	0	1a 1 0	0	LivockLine1	9	Low	Low	High	High	High	High	High	High	High	
BatchEx	10	C	0	3	0.001	30	1a 1 0	0	LivockLine1	10	Low	Low	High	High	High	High	High	High	High	
BatchEx	11	C	0	3	0.001	60	1a 1 0	0	LivockLine1	11	Low	Low	High	High	High	High	High	High	High	
BatchEx	12	C	0	3	0.001	90	1a 1 0	0	LivockLine1	12	Low	Low	High	High	High	High	High	High	High	
BatchEx	13	C	0	4	0.001	0	1a 1 0	0	LivockLine1	13	Low	Low	High	High	High	High	High	High	High	
BatchEx	14	C	0	4	0.001	30	1a 1 0	0	LivockLine1	14	Low	Low	High	High	High	High	High	High	High	
BatchEx	15	C	0	4	0.001	60	1a 1 0	0	LivockLine1	15	Low	Low	High	High	High	High	High	High	High	
BatchEx	16	C	0	4	0.001	90	1a 1 0	0	LivockLine1	16	Low	Low	High	High	High	High	High	High	High	
BatchEx	17	C	0	5	0.001	0	1a 1 0	0	LivockLine1	17	Low	Low	High	High	High	High	High	High	High	
BatchEx	18	C	0	5	0.001	30	1a 1 0	0	LivockLine1	18	Low	Low	High	High	High	High	High	High	High	
BatchEx	19	C	0	5	0.001	60	1a 1 0	0	LivockLine1	19	Low	Low	High	High	High	High	High	High	High	
BatchEx	20	C	0	5	0.001	90	1a 1 0	0	LivockLine1	20	Low	Low	High	High	High	High	High	High	High	
BatchEx	21	C	0	6	0.001	0	1a 1 0	0	LivockLine1	21	Low	Low	High	High	High	High	High	High	High	
BatchEx	22	C	0	6	0.001	30	1a 1 0	0	LivockLine1	22	Low	Low	High	High	High	High	High	High	High	
BatchEx	23	C	0	6	0.001	60	1a 1 0	0	LivockLine1	23	Low	Low	High	High	High	High	High	High	High	
BatchEx	24	C	0	6	0.001	90	1a 1 0	0	LivockLine1	24	Low	Low	High	High	High	High	High	High	High	
BatchEx	25	C	0	7	0.001	0	1a 1 0	0	LivockLine1	25	Low	Low	High	High	High	High	High	High	High	
BatchEx	26	C	0	7	0.001	30	1a 1 0	0	LivockLine1	26	Low	Low	High	High	High	High	High	High	High	
BatchEx	27	C	0	7	0.001	60	1a 1 0	0	LivockLine1	27	Low	Low	High	High	High	High	High	High	High	
.....																				
BatchEx	1197	M	100	10	0.001	0	5 1 0	0	LivockLine	1197	Low	Low	High	High	High	High	High	High	High	
BatchEx	1198	M	100	10	0.001	30	5 1 0	0	LivockLine	1198	Low	Low	High	High	High	High	High	High	High	
BatchEx	1199	M	100	10	0.001	60	5 1 0	0	LivockLine	1199	Low	Low	High	High	High	High	High	High	High	
BatchEx	1200	M	100	10	0.001	90	5 1 0	0	LivockLine	1200	Low	Low	High	High	High	High	High	High	High	

Extern Fault 245



NERC Protection System Misoperations Task Force 2013


Figure 2: NERC-wide Misoperations by Cause Code (Jan 1, 2011 – April 1, 2012)



Advanced Automation & Testing Process

Advanced Automation & Testing Process Used by Quanta Technology

- Conducting RTDS testing is a budget and resource commitment which should not be underestimated.
- Quanta Technology utilized a combination of testing automation and process enhancements to reduce the time it takes to conduct RTDS testing, while simultaneously improving the quality of the results.
- Our goal has been to optimize the process to ensure all necessary tests are conducted as efficiently as possible



Test Plan

Test Plan (tabulated)

Test No.	Fault Position [%]	Fault Location	Type of fault	Rf [ohm]	Angle [Degree]
1001	0.1	F1	AG	0.05	0
1002	0.1	F1	AG	0.05	90
1003	0.1	F1	AB	0.05	150
1004	0.1	F1	AB	0.05	60
1005	0.1	F1	ABG	0.05	0
1006	0.1	F1	ABG	0.05	90
1007	0.1	F1	ABC	0.05	0
1008	0.1	F1	ABCG	0.05	90
1009	30.0	F1	BG	0.05	120
1010	30.0	F1	BG	0.05	30
1011	30.0	F1	BC	0.05	90
1012	30.0	F1	BC	0.05	0

001	0.1	F1	1	0.05	
002	0.1	F1	1	0.05	90
003	0.1	F1	8	0.05	150
004	0.1	F1	8	0.05	60
005	0.1	F1	4	0.05	0
006	0.1	F1	4	0.05	90
007	0.1	F1	7	0.05	0
008	0.1	F1	7	0.05	90
009	30	F1	2	0.05	120
010	30	F1	2	0.05	30
011	30	F1	9	0.05	90
012	30	F1	9	0.05	0

Script input file

Automation



```
...../
Initialization */
...../

string fName = "C:\xy_IB.txt"; /* Input File */
fopen(fName,"r");

for ( k=0 ; k<33 ; k++) /* Increase K for more test cases,
Maximum is 54 *****/

{
  /****** Read from File *****/
  fscanf(fName,"%d",&FLTcase);
  fscanf(fName,"%f",&FLTpercent);
  fscanf(fName,"%s",&FLTLoc);
  fscanf(fName,"%d",&FLTtypeNmb);
  fscanf(fName,"%f",&FLTresist);
  fscanf(fName,"%f",&FLTangle);

  SetSlider "Subsystem #2 : CTLs : Inputs : FltDurxxx2"=150; //10
cycles fault duration
  SetDial "Subsystem #2 : CTLs : Inputs : LGTYPxxx2" = FLTtypeNmb;
  SetSlider "Subsystem #2 : CTLs : Inputs : FltAngxxx2" = FLTangle;
  SetSlider "DraftVariables : Lenxx" = FLTpercent;
  SetSlider "DraftVariables : RP" = FLTresist;
  Start;
  SUSPEND 3;
  PushButton "Subsystem #2 : CTLs : Inputs : FltActxxx2";
  SUSPEND 0.141;
  ReleaseButton "Subsystem #2 : CTLs : Inputs : FltActxxx2";
  SUSPEND 3;
  sprintf(mystring,"C:\x\d_%s",version,FLTcase,version);
  ComtradePlotSave "xxx",mystring;
  SUSPEND 3.00;
  sprintf(mystring,"C:\y\%d_%s",version,FLTcase,version);
  ComtradePlotSave "yyy",mystring;
  SUSPEND 3.00;

  Stop;
}
```

Script program file




Test Results Summary

Test No.	Fault Position [%]	Fault Location	Type of fault	Rf [ohm]	Angle [Degree]
1001	0.1	F1	AG	0.05	0
1002	0.1	F1	AG	0.05	90
1003	0.1	F1	AB	0.05	150
1004	0.1	F1	AB	0.05	60
1005	0.1	F1	ABG	0.05	0
1006	0.1	F1	ABG	0.05	90
1007	0.1	F1	ABC	0.05	0
1008	0.1	F1	ABCG	0.05	90
1009	30.0	F1	BG	0.05	120
1010	30.0	F1	BG	0.05	30
1011	30.0	F1	BC	0.05	90
1012	30.0	F1	BC	0.05	0


Automatically Generated Summary of Test Results

Test No.	Fault Position [%]	Fault description				Comtrade File	Rakegh (all times are in ms)																	
		Fault Location	Type of fault	Rf [ohm]	Angle [Degree]		Tip R	Tip Y	Tip B	Dist Added Op	DEF Trip	DEF Send	DEF Rec	SOTF Trip	Dist Carrier Send	Dist Carrier Rec	Close	AR Start	AR Block	AR pre 3pole	ABB Trip	CB R	CB Y	CB B
1001	0.1	F1	AG	0.05	0	Rakegh_1001_V101	19.2	107.65	1016.6	38.55	-	-	-	-	18.05	38.85	897.1	19.85	944.5	944.85	20.9	49.25	1047.7	1046.65
1002	0.1	F1	AG	0.05	90	Rakegh_1002_V101	19.3	1074.9	1016.6	29.55	-	-	-	-	17.1	26.9	896.65	19.9	942.8	943.6	20.35	48.35	1044.85	1043.65
1003	0.1	F1	AB	0.05	150	Rakegh_1003_V101	19.35	17.7	16.95	27.65	-	-	-	-	17.2	26.9	896.65	19.9	942.8	943.6	20.35	48.4	1047.75	1047.7
1004	0.1	F1	AB	0.05	60	Rakegh_1004_V101	17.95	17.3	16.3	29.3	-	-	-	-	16.65	29.65	895.3	18.55	942.6	943.3	21.75	48	1047.35	1046.35
1005	0.1	F1	ABG	0.05	0	Rakegh_1005_V101	18.15	17.35	17.25	27.5	-	-	-	1127.15	16.95	28	897.3	19.8	942.9	943.2	24.6	48.4	1047.4	1046.9
1006	0.1	F1	ABG	0.05	90	Rakegh_1006_V101	18.6	17.95	16.9	27.95	-	-	-	-	17.55	28.3	896.8	20.25	944.7	944.95	25.7	48.65	1047.85	1046.85
1007	0.1	F1	ABC	0.05	0	Rakegh_1007_V101	18.4	17.5	16.6	27.55	-	-	-	-	17.05	26.65	-	-	61.7	25.1	48.45	47.55	46.65	46.65
1008	0.1	F1	ABCG	0.05	90	Rakegh_1008_V101	18.55	17.8	16.8	27.8	-	-	-	-	17.35	28.15	-	-	52.25	51.7	24.05	48.6	47.65	46.85
1009	30	F1	BG	0.05	120	Rakegh_1009_V101	1927.25	16.7	1019.6	26.55	-	-	-	-	18.05	26.85	897.15	18.9	943.3	944.95	25.85	1051.3	1049.65	1049.65
1010	30	F1	BG	0.05	30	Rakegh_1010_V101	1942.65	18	1044	28.9	-	-	-	-	17.35	29.4	896.95	20.1	943.35	945.15	26.7	1075.7	1074.85	1074.05
1011	30	F1	BC	0.05	90	Rakegh_1011_V101	20.4	19.6	18.75	29.75	-	-	-	-	19.35	30.2	899.25	21.9	944.05	947.25	23.3	50.45	49.65	48.8
1012	30	F1	BC	0.05	0	Rakegh_1012_V101	18.15	19.5	18.5	26.4	-	-	-	-	19.05	26.75	899.55	22.75	949.15	947.65	23.75	50.2	49.55	48.55
1013	30	F1	BCG	0.05	120	Rakegh_1013_V101	18.6	19.05	17.9	27.9	-	-	-	-	17.3	28.2	898.05	20.15	943.05	945.5	21.1	48.65	49.1	47.85
1014	30	F1	BCG	0.05	30	Rakegh_1014_V101	20.2	19.6	18.65	27.9	-	-	-	-	19.15	27.15	901.35	22.95	946.9	948.65	21.45	50.25	49.65	48.7
1015	30	F1	BCA	0.05	120	Rakegh_1015_V101	20.8	21	20.1	25.05	-	-	-	-	19.45	25.45	-	-	55.1	64.75	21.6	50.85	51.65	50.15
1016	30	F1	BCAB	0.05	30	Rakegh_1016_V101	20.95	19.95	19.1	28.1	-	-	-	-	19.65	27.55	-	-	55	65.05	23.35	51	50	49.15
1017	70	F1	CG	0.05	60	Rakegh_1017_V101	1075.2	1074.4	28.35	29.3	-	-	-	-	24.75	27.5	908	29.65	955.55	955.65	25.45	1106.25	1104.45	108.4
1018	70	F1	CG	0.05	150	Rakegh_1018_V101	1037.35	1036.8	23.8	24.7	-	-	-	-	24.15	22	903.35	26	949	952.4	25.6	1067.4	1066.85	53.85
1019	70	F1	CA	0.05	30	Rakegh_1019_V101	25.8	24.95	25.2	25.1	-	-	-	-	24.65	23.2	903.4	26.5	947.7	951.1	25.7	55.85	55	55.25
1020	70	F1	CA	0.05	120	Rakegh_1020_V101	25.7	25.1	24.4	24.05	-	-	-	-	23.55	22.3	902.6	25.4	950.25	950.1	22.4	55.75	55.15	54.45
1021	70	F1	CAB	0.05	60	Rakegh_1021_V101	25.75	25.1	24.1	25.1	-	-	-	-	23.4	25.3	902.35	25.5	950.8	951.2	25.1	55.8	55.15	54.15
1022	70	F1	CAB	0.05	150	Rakegh_1022_V101	29.75	29.2	28.4	29	-	-	-	-	23.6	29.35	907.3	29.25	951.5	954.65	21.7	59.8	59.25	58.45
1023	70	F1	CABG	0.05	60	Rakegh_1023_V101	29.95	29.45	28.3	29.25	-	-	-	-	23.65	29.55	-	-	61.55	70.85	21.75	60.2	59.1	58.35
1024	70	F1	CABG	0.05	150	Rakegh_1024_V101	26	25.35	24.25	25.3	-	-	-	-	23.8	25.55	-	-	57.5	67.05	23.45	56.05	55.4	54.3
1025	99	F1	AG	0.05	0	Rakegh_1025_V101	29.4	1104.8	1103.7	28.7	-	-	-	-	24.1	28.2	906.9	28.95	953.1	956.6	21.1	59.45	1134.85	1133.75
1026	99	F1	AG	0.05	90	Rakegh_1026_V101	25.45	1090.05	1088.8	23.8	-	-	-	-	23.25	23.95	903.25	25.05	947.75	951.1	23.65	55.5	1120.1	1118.85
1027	99	F1	AB	0.05	150	Rakegh_1027_V101	28.75	27.85	26.85	27.85	-	-	-	-	27.3	27.65	906.35	29.15	953.55	953.85	27.35	58.8	57.9	56.9
1028	99	F1	AB	0.05	60	Rakegh_1028_V101	29.95	29.15	29.2	29.15	-	-	-	-	23.6	29.5	907.3	30.5	952.25	955	25.45	60	59.2	59.25
1029	99	F1	ABG	0.05	0	Rakegh_1029_V101	25.35	24.6	23.9	23.65	-	-	-	1196.2	23.2	20.85	902.85	24.45	949.35	950.3	22.65	55.4	54.65	53.85
1030	99	F1	ABG	0.05	90	Rakegh_1030_V101	28.15	27.8	26.8	27.8	-	-	-	1137.5	23.25	26.1	905.9	28.05	953.3	953.4	55.5	59.2	57.85	56.85
1031	99	F1	ABC	0.05	0	Rakegh_1031_V101	25.75	24.85	23.9	23.9	-	-	-	-	23.4	21.15	-	-	56.6	67.05	19.5	58	54.9	53.95
1032	99	F1	ABCG	0.05	0	Rakegh_1032_V101	24.55	24.75	23.8	23.65	-	-	-	-	23.35	21	-	-	55.8	65.95	21.86	54.6	54.8	53.85
1033	99	F1	ABCG	0.05	90	Rakegh_1033_V101	25.1	24.55	23.4	23.45	-	-	-	-	22.9	22.7	-	-	56.55	65.85	22.2	55.15	54.6	53.45

Standard RTDS output -> n-COMTRADE files





Hyperlink functionality for detailed review




Process Automation



Test Case #	Fault location	Percent	Fault Type	Fault Duration (cycle)	Fault Angle	Fault Resistor	Load
144_1201	A	0.00	AG	12	0	5	Case #1a
144_1202	A	0.00	BG	12	30	5	Case #1b
144_1203	A	0.00	CG	12	60	5	Case #1c
144_1204	A	0.00	CG	12	90	5	Case #1d
144_1205	A	0.00	AG	12	0	5	Case #1e
144_1206	A	0.00	ABG	12	30	5	Case #1f
144_1207	A	0.00	BC	12	60	5	Case #1g
144_1208	A	0.00	ABC	12	90	5	Case #1h
144_1209	A	0.00	CA	12	0	5	Case #1i
144_1210	A	0.00	CAG	12	30	5	Case #1j



Test Case #	Fault Location	Percent	Fault Type	Fault Duration (Cycle)	Fault Angle	Fault Resistor	Load	Test Comm Block	RTDS Comm Block
144_1201	A	0.001	AG	12	0	5	Case #1a	1	0
144_1202	A	0.001	BG	12	30	5	Case #1b	1	0
144_1203	A	0.001	CG	12	60	5	Case #1c	1	0
144_1204	A	0.001	CG	12	90	5	Case #1d	1	0
144_1205	A	0.001	AG	12	0	5	Case #1e	1	0
144_1206	A	0.001	ABG	12	30	5	Case #1f	1	0
144_1207	A	0.001	BC	12	60	5	Case #1g	1	0
144_1208	A	0.001	ABC	12	90	5	Case #1h	1	0
144_1209	A	0.001	CA	12	0	5	Case #1i	1	0
144_1210	A	0.001	CAG	12	30	5	Case #1j	1	0



Conclusion

- To select appropriate number of test cases is a difficult task
- Time and budget constrains often dictate number of test cases
- Automation enables more effective testing

Thank you!

Quanta Technology, LLC
4020 Westchase Blvd., Suite 300
Raleigh, NC 27607



(919) 334-3000



quanta-technology.com



info@quanta-technology.com



Facebook.com/quanta-technology-LLC



[@QuantaTech](https://twitter.com/QuantaTech)



Linkedin.com/company/quanta-technology

