




RTDS in the Dominion Energy Blackstart Study

Dr. Ren Liu
Dominion Energy


Dominion Energy Virginia/NC

- **Electric Transmission**
 - 6,600 miles of transmission lines in Virginia, North Carolina and West Virginia
- **Electric Distribution**
 - 57,600 miles of distribution lines in Virginia and North Carolina
 - Serves 2.6 million customers



About Blackstart


- Energizing the grid from total blackout
- Has never happened in mainland USA
- Need to be prepared



Hurricane Maria

System Restoration Plan (SRP) study


- Began in 2013, on-going today
- Lead: ET Operations Engineering
- Internal Collaboration:
 - ET System Protection Engineering
 - ET SOC
 - ET Planning
 - Dominion Generation
 - Dominion Distribution



Major tasks


- Study the feasibility of the paths (Load flow study)
- Study blackstart path dynamic behaviors
- Validate existing protection schemes
- Real-time decision support tool

Load Flow Studies




- Voltage
- Generation output (MW, Mvar)


PSS/E study example




PSS/E study example




PSS/E study example




PSS/E study example




PSS/E study example



PSS/E study example



PSS/E study example



- All voltages are maintained within 1 ± 0.05 p.u. for energized system nodes
- More loads can be picked up when more black out area is energized


Bus status for restoration path A

Bus	Base (kV)	Step 1-2		Step 3-4		Step 5-7	
		Voltage (p.u.)	Angle (deg)	Voltage (p.u.)	Angle (deg)	Voltage (p.u.)	Angle (deg)
1	13.8	1.0087	-51.29	1.0087	-51.29	1.0087	-51.29
2	230	1.0087	-53.53	1.0087	-54.01	1.0087	-54.28
3	230	1.0082	-53.81	1.0082	-54.29	1.0082	-54.56
4	230	1.0075	-53.95	1.0075	-54.43	1.0075	-54.7
5	500	1.0327	-53.95	1.0327	-54.43	1.0327	-54.7
6	230	1.0087	-53.53	1.0086	-54.05	1.0087	-54.32
7	230	1.0087	-53.53	1.0085	-54.07	1.0087	-54.35
8	13.8	1.0047	-53.48	1.0126	-50.67	1.0025	-50.89
9	230	-	-	1.0083	-54.13	1.0087	-54.42
10	230	-	-	1.0071	-54.4	1.0086	-54.73
11	115	-	-	1.0016	-54.19	1.0018	-54.47
12	230	-	-	1.007	-54.43	1.0086	-54.76
13	230	-	-	1.0075	-54.43	1.0105	-54.81
14	230	-	-	-	-	1.0111	-54.84
15	230	-	-	-	-	1.0116	-54.89
16	115	-	-	-	-	1.0048	-54.94
17	230	-	-	-	-	1.0116	-54.89

Machine status for restoration path A



Machine	Base (kV)	PMax (MW)	Step 1-2		Step 3-4		Step 5-7		Power Reserve (MW)
			PGen (MW)	QGen (MVAR)	PGen (MW)	QGen (MVAR)	PGen (MW)	QGen (MVAR)	
1	13.8	72	33.214	-0.2089	40.342	-0.0849	44.369	0.011509	27.631
2	13.8	72	0.6	-3.3915	50	3.4845	50	-5.04305	22

Load flow study vs dynamic study



Dynamic study for Blackstart

- Transient response
- Generator control
 - Voltage control
 - Frequency control
- Island synchronization
- Protection validation



RTDS Lab in Dominion Energy



RTDS




Hardware under test:
Relay, GPS clock,
Substation computer,
FACTS controller



- Multiple analog I/O and digital I/O
- Advanced Studies: Root cause analysis, FACTS, Harmonics, Blackstart, Protection, Inverter testing, etc

Dynamic study of Blackstart in RTDS



Dynamic analysis



Synchronization of islands




Protection validation

Dynamic analysis of Blackstart



- All the cranking paths are built in RTDS
- Dynamic response of each step is simulated
- Lots of efforts
 - Network reduction
 - Model validation (on-going process)

RSCAD model of a particular path




Dynamic simulation in RTDS

- Dynamic responses are captured after each switching step
- The frequency and voltages should remain within the acceptable limits




- Frequency and voltage response after a switching step

Islands synchronization



Islands synchronization Example




Islands synchronization Simulation Results

Thresholds:

- 5 degrees
- 0.1 Hz
- 5% voltage mag diff


Breaker Control

Name	Description	Value	Unit	Min	Max
StrValAdiff	Maximum Angle Difference	15	degrees	0.0	100.00
StrValFdiff	Maximum Slip Frequency (pickup)	0.2	Hz	0.0	3.0
StrValVdiff	Maximum Voltage Difference	5.0	%	0.0	20.00
FgenH	V1 Frequency > V2 Frequency	NO		0	1
VgenH	V1 Voltage > V2 Voltage	NO		0	1
StrVal27S1	Minimum V1 Voltage	0.5	volts	0.5	200.0
StrVal27S2	Minimum V2 Voltage	0.5	volts	0.5	200.0
DeadBus	Enable Dead Bus (V2) Check	YES		0	1



Protection validation: Hardware-in-the-loop


- Relay should operate correctly during the restoration
- Much different condition during blackstart



Hardware-in-the-Loop Relay Testing

- Possible Problems:
 - The fault current may be less than the relay pick up current.
 - Time inverse overcurrent functions may respond slower than normal.
 - The relay may misoperate when the fault happens during the blackstart switching transient.
- Following conditions are tested:
 - Normal blackstart switching operation should not trigger protection relays
 - Relays should operate correctly towards faults during blackstart steady state operation
 - Relays should operate correctly towards faults during blackstart switching operation

Zone 1-Single Phase to Ground Fault during blackstart steady state



Faults: Zone 1, A phase to ground fault


Results:

- Relay takes two cycles to trip the circuit breaker


- Relay front panel shows:

- TRIP
- INST
- ZONE1
- PHASE A
- GROUND

- Relay operated properly.




Zone 2-Phase to Phase Fault during blackstart steady state




Faults: Zone 2, A phase to C phase fault

Results:

- Time-delayed backup Relay function waits for half second, then trips the circuit breaker
- Relay front panel shows:
 - TRIP
 - TIME
 - ZONE2
 - PHASE A
 - PHASE C
- Relay operated properly.




Zone 1-Single Phase to Ground Fault during blackstart switching operation




Faults: Zone 1, A phase to ground fault
 Time: Fault happens when energize Transmission Line
 Results:


- Relay takes **three cycles** to send trip to the circuit breaker
- Relay front panel shows:
 - TRIP
 - INST
 - ZONE 1
 - PHASE A
 - GROUND
- Relay operation is delayed by switching.




Time-Inverse Overcurrent Backup Protection Scheme Test



Small Load (5MW) Relay trip at 2.3s



Large Load (40MW) Relay trip at 3.3s



Larger Load (80MW) Relay didn't trip

Faults: A phase to ground unbalanced fault
Relay:

- Time-inverse overcurrent backup protection scheme
- Primary line distance protection is disabled.


Results:

- **Overcurrent backup protection scheme is delayed and did NOT operate.**


Real-time decision support



Power Grid



SOC



Conclusion

- In the future, RTDS will be used extensively in Dominion blackstart studies, such as:
 - Improve generator and load modeling (PMU, DFR)
 - Validate more complicated protection schemes
 - Automate the process for different paths in SRP
 - Refine the communication procedure/method with SOC
 - Real-time decision support
- RTDS will play much more important role in blackstart

Questions?

If you have additional questions, please contact me at:
Dr. Ren Liu ren.liu@dominionenergy.com